

<p>PROJECT: PROPOSED PIPELINE LAY OUT FOR RWIBIKWATO/T/ C TO MIDORA WATER EXTENSION IN KAMWENGE DISTRICT</p>	
<p>CLIENT: JOINT EFFORT TOSAVE THE ENVIRONMENT</p>	
<p>FUNDIER: JOIN FOR WATER</p>	
<p>DATE: OCTOBER 2024</p>	
<p>DRAWN BY: WASH TECHNICIAN</p>	<div data-bbox="239 772 406 929" style="border: 1px solid black; border-radius: 50%; padding: 5px; display: inline-block;"> <p>Existing NWSG 75mm dia stand at Kwevika (wa T/C proposed start point of Water ext.)</p> </div> <div data-bbox="454 1153 502 1377" style="border: 1px solid black; padding: 5px;"> <p>WATER EXTENSION DETAILS: Piped Line to be of HDPE PN16 of length 4.3km</p> <ol style="list-style-type: none"> 1. HDPE 63mm Dia Pipeline: 3.23km 2. HDPE 50mm Dia Pipeline: 1.07km 3. Public Tap stand (PTS): 5 in No. & metered installed at agreed location 4. There shall be 1 Bulk meter & Flanged gate/hall valve installed at the the beginning of water ext 5. Pipe line excavation shall be at a depth Min. 0.9meters </div>